



EFFECTIS ERA AVRASYA TEST ve BELGELENDİRME AŞ

Dilovası OSB Mahallesi Fırat Caddesi No: 18

Dilovası, Kocaeli / TÜRKİYE

www.effectis.com

DECLARATION OF TEST RESULTS

No: EEA – 2100 – 0073

The fire resistance test was carried out for the product as described below at Efectis Era Avrasya Test Laboratory on 06.08.2021 in accordance with the test standard:

DIN 4102-12:1998

Cable Supporting System – Power cables fixed on cable trays and cable ladders

FIRE RESISTANCE CLASSIFICATION					
CABLE TRAYS	POSITION 1 K60A60020S	POSITION 2 K75A20012SS1	POSITION 3 K75A20010SS1	POSITION 4 K40A20020S	POSITION 5 K60A20015SS2
CABLE TYPE	(N)HXCH 4x50/25	(N)HXCH 4x50/25	(N)HXCH 4x50/25	(N)HXCH 4x50/25	(N)HXCH 4x50/25
TIME (MIN.)	42	90	63	48	90
CLASS.	E30	E90	E60	E30	E90
CABLE TRAYS	POSITION 6 K60M40020	POSITION 7 K40M40015S	POSITION 8 K60A40020S	POSITION 9 K60A30015SS2	POSITION 10 K60A40015SS2
CABLE TYPE	(N)HXCH 4x50/25	(N)HXCH 4x50/25	(N)HXCH 4x50/25	(N)HXCH 4x50/25	(N)HXCH 4x50/25
TIME (MIN.)	77	77	44	90	90
CLASS.	E60	E60	E30	E90	E90
CABLE TRAYS	POSITION 11 K75A40012SS1	POSITION 12 K40A30020S	POSITION 13 K60A30015	POSITION 14 K75A30012SS1	
CABLE TYPE	(N)HXCH 4x50/25	(N)HXCH 4x50/25	(N)HXCH 4x50/25	(N)HXCH 4x50/25	
TIME (MIN.)	90	39	38	58	
CLASS.	E90	E30	E30	E30	

Placed on the market by:

KIRAÇ METAL ÜRÜNLERİ SAN. VE TİC. LTD. ŞTİ.

75. Yıl Organize Sanayi Bölgesi Şehitler Bulvarı No:21 Odunpazarı,
Eskişehir/TURKEY

Manufactured by:

KIRAÇ METAL ÜRÜNLERİ SAN. VE TİC. LTD. ŞTİ.

75. Yıl Organize Sanayi Bölgesi Şehitler Bulvarı No:21 Odunpazarı,
Eskişehir/TURKEY

Ali BAYRAKTAR
Laboratory Manager
06.09.2021

This document is a declaration of test results and does not represent any type of approval or certification of the product. All details related to product specifications and field of applications are described in the report No: RFTR21162.

